

Ningbo Ginlong Technologies Co., Ltd.

# **CERTIFICATION OF CONFORMITY**

## Manufacturer: Ningbo Ginlong Technologies Co., Ltd.

Address: No.57 jintong Road, Seafront (Binhai) Industrial park, Xiangshan Demonstration Industrial Estate, Xiangshan, Ningbo, Zhejinag, 315712, P.R. China

# Product: Automatic disconnection device between a generator and the public low-voltage grid

Model: Solis-EPM3-5G-Plus

#### Use in accordance with regulations:

Technical Guidance for Customer Export Limiting Schemes G100 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply.

#### **Applied rules and standards :**

The result according to G100 engineering recommendation.

The safety concept of an aforementioned representative product complies at the time of issue of this certificate of valid safety specifications for the specified use in accordance with G100 recommendations.

Compliant with BSEN 61000-3-2

Certificate Number: GLDQ190820

宁波锦浪新能源科技有限公司

NINGBO GINLONG TECHNOLOGIES CO., LTD.

Date: 2019-09-04

**Manufacture Stamp** 

Date and place Ningbo 2019-09-04

Zhang Kun



Ningbo Ginlong Technologies Co., Ltd.

#### System Connecton Diagram



# **Setting Protection Test**

Requirement	Result	Note
The settings is password protected, and cannot be changed by	Pass	
anyone other than got written agreement of the DNO;		

#### **Fail Safe Test**

Method: Set 50% export limit, implement the test before start or in running

Criteria: Fall time is less than 5s, the inverter's output active power is less than set limit. After fail safe test, disconnect AC, the reconnect time delay is fault reconnect time.

No	Componen t	Test	Active Power	Response Time	Fall Time	Reconnec t time	Pass /Fail	Comments
1	Remove	Remove CT	30kW	1.538	1.68	3.0S	pass	Fail safe control function integrated inside EPM.
	СТ	Disconnect CT Cable	30kW	1.558	1.78	3.2 S	pass	Fail safe control function integrated inside EPM.
2	Power Monitoring Unit(PMU	Remove Power supply	30kW	1.09 S	1.3S	27.1S	pass	Fail safe control function



	)	to PMU						integrated
	,							inside EPM.
3	Control Unit(CU)	Remove Power supply to any CU	30kW	1.14S	1.1S	25.88	pass	Fail safe control function integrated inside EPM.
4	Generator Interface units(GIU)	Remove Power supply to all GIUs	NA	NA	NA	NA	NA	NA
5	Demand control unit(DCU)	Remove Power supply to all DCU	NA	NA	NA	NA	NA	NA
6	Network hub/switch es	Remove Power supply	NA	NA	NA	NA	NA	NA
7	PMU →CU communic ation cable	Unplug cable	NA	NA	NA	NA	NA	Same control unit of the EPM
8	CU →GIU communic ation cable	Unplug cable(repeat where additional GIU units)	30kW	2.1 S	2.65	3.28	pass	Fail safe control function integrated inside EPM.
9	GIU→ communic ation cable	Unplug cable(repeat where additional GIU units)	30kW	2.28	2.58	3.68	pass	Fail safe control function integrated inside inverter.
10	CU $\rightarrow$ DCU communic ation cable	Unplug cable(repeat where additional DCU units)	NA	NA	NA	NA	NA	NA
11	DCU→ Load communic ation cable	Unplug cable(repeat where additional DCU units)	NA	NA	NA	NA	NA	NA
12	Controlled	Turn off	30kW	1.8S	2.36	5.5S	pass	



Ningbo Ginlong Technologies Co.,Ltd.

 1		1	1	1	
Load(s)	load				NA
	(e.g. active				
	thermostat)				

# **Power Limit Test**

Method: Set export limit, implement the test before start, then start the inverter.

Criteria: fall time is less than 5s, the inverter's export active power is less than limit power.

0%expo	0%export limit [% Inverter Rating]								
	Input Input supply [% Inverter Rating]								
Load Ex	Load Expot/Time 25% 50% 75% 100%								
Load	0%	14670w/4.4S	29440w/3.8S	44280w/3.6S	60430w/2.9S				
[%	25%	NA	29460w/3.4S	44320w/3.5S	60480w/2.8S				
Inverter	50%	NA	NA	44300w/3.5S	60620w/2.5S				
Rating]	75%	NA	NA	NA	60460w/2.0S				

25%export limit [% Inverter Rating]									
	Input Input supply [% Inverter Rating]								
Load Ex	Load Expot/Time 25% 50% 75% 100%								
Load	0%	NA	29860w/3.6S	44510w/3.0S	60490w/2.7S				
[%	25%	NA	NA	44500w/2.9S	60650w/2.5S				
Inverter	50%	NA	NA	NA	60460w/2.2S				
Rating]	75%	NA	NA	NA	NA				

50%exp	50%export limit [% Inverter Rating]							
	Input Input supply [% Inverter Rating]							
Load Expot/Time 25% 50% 75% 100%								
Load	0%	NA	NA	44970w/2.8S	60600w/2.4S			
[%	25%	NA	NA	NA	60580w/2.1S			
Inverter	50%	NA	NA	NA	NA			
Rating]	75%	NA	NA	NA	NA			

75%exp	75%export limit [% Inverter Rating]								
	Input Input supply [% Inverter Rating]								
Load Ex	Load Expot/Time 25% 50% 75% 100%								
Load	0%	NA	NA	NA	60650w/2.0S				
[%	25%	NA	NA	NA	NA				
Inverter	50%	NA	NA	NA	NA				
Rating]	75%	NA	NA	NA	NA				

### Comments

The test result is based on Solis-60K-4G. All the series of inverters control command are the same. So the test result can cover all series.